





	ROUND LINE <	A CROIL	E	SEE LATCH DETAIL	SEE HII DETAIL  GROUND LINE  SEE LIF NUT DE
B FRONT VIEW		>	<	C D VIEW	_ <del>&gt;</del>
	MODEL	OVERALL HEIGHT	OVERALL WIDTH AT BOTTOM	OVERALL DEPTH AT BOTTOM	MAXIMUM RECCOMENDE BURIAL DEPTI SEE NOTE 1

MDDEL No.	OVERALL HEIGHT	□VERALL WIDTH AT B□TT□M	□VERALL DEPTH AT B□TT□M	MAXIMUM RECCOMENDED BURIAL DEPTH SEE NOTE 1
	Α	В	С	D
CJP-40-41	41"	81.1/4"	46.1/4*	17"
CJP-40-50	50'	83.1/4"	48.1/4*	26*
CJP-40-56	56 <b>′</b>	84.3/4"	49.3/4*	32*

SCHEMATIC

MDDEL No.	OVERALL HEIGHT	□VERALL WIDTH AT B□TT□M	□VERALL DEPTH AT B□TT□M	MAXIMUM RECCOMENDED BURIAL DEPTH SEE NOTE 1	
	Α	В	С	D	
CJP-40-41	41"	81.1/4"	46.1/4*	17"	
CJP-40-50	50'	83.1/4"	48.1/4*	26*	
CJP-40-56	56*	84.3/4"	49.3/4*	32*	

MATERIAL LIST - STANDARD UNIT DESCRIPTION ITEM POWER DESIGN INC MODEL NO CJP-40 FIBERGLASS CABLE JUNCTION PEDESTAL - MUNSELL GREEN ALUMINUM JUNCTION MOUNTING BAR AND PARKING CLIP MOUNTING RAILS ADJUSTABLE LOCATION STAINLESS STEEL PARKING CLIPS

## OPTIONAL EQUIPMENT

200 AMP LOADBREAK JUNCTION - 35KV - SPECIFY MANUFACTURER AND 2, 3, DR 4-WAY

## NOTE:

1. ORDERING INFORMATION:

USER SHOULD SELECT 'D', BURIAL DEPTH, DESIRED. SPECIFY "A", DVERALL HEIGHT, AS A SUFFIX TO THE BASIC PART NO. i.e.; CJP-40-50 = 50" DVERALL HEIGHT 8" TERMINAL HEIGHT MAY BE INCREASED BY DECREASING BURIAL DEPTH OR ORDERING THE NEXT SIZE GREATER "A" DIMENSION.

- - 1) FIBERGLASS LAMINATE 3/16' NUMINAL THICKNESS
  - 2) EXTERIOR UV STABILIZED GELCOAT 14 MIL NOMINAL THICKNESS - WHITE INTERIOR
  - 3) FIRE RETARDANT DOES NOT SUPPORT COMBUSTION
  - 4) STAINLESS STEEL HARDWARE
- 3. MOUNTING BAR WILL WITHSTAND A MINIMUM 400 LB. LOADING TO INSTALL OR REMOVE ELBOWS.
- 4. EQUIPMENT SHOWN IS THE LARGEST INTERFACE THREE PHASE RATED. CLEARANCES MAY BE INCREASED WITH DITHER MANUFACTURER'S EQUIPMENT

DEADFRONT CABLE JUNCTION PEDESTAL

35KV 200 AMP 150KV BIL

THREE PHASE 2, 3, DR 4-WAY LOADBREAK JUNCTION



FILE REF