


M□DEL No.	OVERALL HEIGHT	OVERALL WIDTH AT BOTTOM	□VERALL DEPTH AT B□TT□M	MAXIMUM RECCOMENDED BURIAL DEPTH SEE NOTE 1
	Α	В	С	D
CJP-43-41	41*	81.1/4"	46.1/4"	17"
CJP-43-50	CJP-43-50 50°		48.1/4*	26*
CJP-43-56	56 '	84.3/4*	49.3/4"	32*

FILE REF



	MATERIAL LIST - STANDARD UNIT					
ITEM	DESCRIPTION					
1	POWER DESIGN INC MODEL NO CJP-43 FIBERGLASS CABLE JUNCTION PEDESTAL - MUNSELL GREEN					
2	ALUMINUM JUNCTION MOUNTING BAR AND MOUNTING CLIPS					
3	STAINLESS STEEL PARKING CLIPS					

OPTIONAL EQUIPMENT

51 200 AMP LOADBREAK JUNCTION - 35KV - 150KV BIL - SPECIFY 2, 3 OR 4-WAY AND MANUFACTURER

NOTE:

1. ORDERING INFORMATION:

USER SHOULD SELECT 'D', BURIAL DEPTH, DESIRED.
SPECIFY 'A', OVERALL HEIGHT, AS A SUFFIX TO THE BASIC PART NO.
i.e., CJP-43-50 = 50' DVERALL HEIGHT
6.1/2' TERMINAL HEIGHT MAY BE INCREASED BY DECREASING
BURIAL DEPTH OR ORDERING THE NEXT SIZE GREATER 'A' DIMENSION.

. MATERIAL:

- 1) FIBERGLASS LAMINATE 3/16' NOMINAL THICKNESS
- 2) EXTERIOR UV STABILIZED GELCOAT 14 MIL NOMINAL THICKNESS WHITE INTERIOR
- 3) FIRE RETARDANT DOES NOT SUPPORT COMBUSTION
- 4) STAINLESS STEEL HARDWARE
- 3. MOUNTING BAR WILL WITHSTAND A MINIMUM 400 LB. LOADING TO INSTALL OR REMOVE ELBOWS.
- EQUIPMENT SHOWN IS THE LARGEST INTERFACE THREE PHASE RATED. CLEARANCES MAY BE INCREASED WITH OTHER MANUFACTURER'S EQUIPMENT

DEADFRONT CABLE JUNCTION PEDESTAL

35KV 200 AMP 150KV BIL

THREE PHASE 2, 3 DR 4-WAY LOADBREAK/DEADBREAK JUNCTIONS



DRAWN:	PAGE	DATE	DRAWING NO.
RB		3-29-04	3365-R1