


MDDEL No.	OVERALL HEIGHT	OVERALL WIDTH AT BOTTOM	OVERALL DEPTH AT BOTTOM	MAXIMUM RECCOMENDED BURIAL DEPTH SEE NOTE 1
	Α	В	С	D
CJP-43-41	41*	81.1/4"	46.1/4*	17*
CJP-43-50	50*	83.1/4*	48.1/4*	26*
CJP-43-56	56*	84.3/4*	49.3/4*	32*

SCHEMATIC



	MATERIAL LIST - STANDARD UNIT			
ITEM	DESCRIPTION			
1	POWER DESIGN INC MODEL NO CJP-43 FIBERGLASS CABLE JUNCTION PEDESTAL			
2	ALUMINUM JUNCTION MOUNTING BAR			
3	STAINLESS STEEL PARKING CLIPS			

OPTIONAL EQUIPMENT

600 AMP DEADBREAK JUNCTION - 35KV - 150KV BIL - SPECIFY MANUFACTURER AND 2, 3, OR 4-WAY

NOTE:

1. DRDERING INFORMATION:

USER SHOULD SELECT "D", BURIAL DEPTH, DESIRED. SPECIFY 'A', DVERALL HEIGHT, AS A SUFFIX TO THE BASIC PART NO. I.e., CJP-43-50 = 50" DVERALL HEIGHT 7.3/4" TERMINAL HEIGHT MAY BE INCREASED BY DECREASING BURIAL DEPTH OR ORDERING THE NEXT SIZE GREATER "A" DIMENSION.

2. MATERIAL:

- 1) FIBERGLASS LAMINATE 3/16' NUMINAL THICKNESS
- 2) EXTERIOR UV STABILIZED GELCOAT 14 MIL NOMINAL THICKNESS - WHITE INTERIOR
- 3) FIRE RETARDANT DOES NOT SUPPORT COMBUSTION
- 4) STAINLESS STEEL HARDWARE
- 3. MOUNTING BAR WILL WITHSTAND A MINIMUM 400 LB. LOADING TO INSTALL OR REMOVE ELBOWS.
- 4. EQUIPMENT SHOWN IS THE LARGEST INTERFACE THREE PHASE RATED. CLEARANCES MAY BE INCREASED WITH OTHER MANUFACTURER'S EQUIPMENT

DEADFRONT CABLE JUNCTION PEDESTAL

600 AMP

150KV BIL

THREE PHASE

2, 3, DR 4-WAY DEADFREAK JUNCTION



FILE REF