



_	SCHEMATIC	

M□DEL No.	OVERALL HEIGHT	□VERALL WIDTH AT B□TT□M	□VERALL DEPTH AT B□TT□M	MAXIMUM RECCOMENDED BURIAL DEPTH SEE NOTE 1
	Α	В	С	D
CJP-84-41	41*	98.1/4*	40"	17"
CJP-84-50	50 ′	99*	41*	20*
CJP-84-56	56 '	99.3/4*	41.1/2"	26*

FILE REF

No	HEIGHT	BOTTOM	BOTTOM	BURIAL DEPTH SEE NOTE 1
	Α	В	С	D
CJP-84-41	41"	98.1/4"	40"	17"
CJP-84-50	50 ′	99*	41"	20*
CJP-84-56	56 ′	99.3/4*	41.1/2*	26*

		MATERIAL LIST - STANDARD UNIT		
	ITEM	DESCRIPTION		
	1	POWER DESIGN INC MODEL NO CJP-84 FIBERGLASS CABLE JUNCTION PEDESTAL - MUNSELL GREEN		
	2	ALUMINUM JUNCTION MOUNTING BARS AND PARKING CLIP MOUNTING BARS		
Ξ	3	STAINLESS STEEL PARKING CLIPS		

	UPTIUNAL EQUIPMENT
	200 AMP LOADBREAK JUNCTION - 15/25KV - 95/125KV BIL - SPECIFY VOLTAGE & 2, 3, DR 4-WAY
52	600 AMP DEADBREAK JUNCTION - 15/25KV - 95/125KV BIL - SPECIFY VOLTAGE & 2, 3, OR 4-WAY

NOTE:

1. ORDERING INFORMATION:

USER SHOULD SELECT 'D', BURIAL DEPTH, DESIRED. SPECIFY "A", DVERALL HEIGHT, AS A SUFFIX TO THE BASIC PART NO. I.e.; CJP-84-50 = 50" DVERALL HEIGHT 24" TERMINAL HEIGHT MAY BE INCREASED BY DECREASING BURIAL DEPTH OR ORDERING THE NEXT SIZE GREATER "A" DIMENSION.

MATERIAL:

- 1) FIBERGLASS LAMINATE 3/16' NOMINAL THICKNESS
- 2) EXTERIOR UV STABILIZED GELCOAT 14 MIL NOMINAL THICKNESS - WHITE INTERIOR
- 3) FIRE RETARDANT DOES NOT SUPPORT COMBUSTION
- 4) STAINLESS STEEL HARDWARE
- 3. MOUNTING BAR WILL WITHSTAND A MINIMUM 400 LB. LOADING TO INSTALL OR REMOVE ELBOWS.

DEADFRONT CABLE JUNCTION PEDESTAL

15/25KV 200 AMP 95/125KV BIL

THREE PHASE 2, 3 DR 4-WAY LOADBREAK JUNCTIONS

